

**APPENDIX C
FIRE HYDRANT
COLOR CODE SCHEME**

GENERAL INSTRUCTIONS

To insure that a uniform color code scheme is used throughout the Town when installing fire hydrants, the following color code shall be used.

A. CLASSIFICATION OF HYDRANTS

Fire hydrants shall be painted in a uniform color coding scheme in order to designate the rated flow capacities (at 20 psi (1.4 bar) residual pressure or other designated value) as follows:

Light Blue	Rated capacity of 1,500 gpm or greater
Green	Rated capacity of 1,000-1,499 gpm
Orange	Rated capacity of 500-999 gpm
Red	Rated capacity of less than 500 gpm

B. MARKING OF HYDRANTS

All barrels should be red unless otherwise designated by the local utility district. The tops and nozzle caps shall be painted

For rapid identification at night, the capacity colors shall be of a reflective-type paint.

Hydrants rated at less than 20 psi (1.4 bar) shall have the rated pressure stenciled in black on the hydrant top.